


# Diagnostics of photovoltaic power plants operation



**Vitezslav Benda,**  
CTU Prague, Faculty of Electrical Engineering



## Very fast development of Photovoltaics in the past decade



**2004 - 1GW<sub>p</sub> installed in EU**


**2006 - 3 GW<sub>p</sub> installed in EU**

**2010 - 29 GW<sub>p</sub> installed in EU**

**2011 - 50 GW<sub>p</sub> installed in EU**

**2012 - 63 GW<sub>p</sub> installed in EU**



In the end of 2012 was installed in the World **102 GW<sub>p</sub>**



**2010**  
**Germany** 17 GW<sub>p</sub>  
**ROE** 12 GW<sub>p</sub>  
**ROW** 10 GW<sub>p</sub>


**2011**  
**Germany** 25 GW<sub>p</sub>  
**ROE** 25 GW<sub>p</sub>  
**ROW** 17 GW<sub>p</sub>


**2012**  
**Germany** 32 GW<sub>p</sub>  
**ROE** 31 GW<sub>p</sub>  
**ROW** 38 GW<sub>p</sub>




100 GW<sub>p</sub> ~ 800 km<sup>2</sup> of PV modules

# PV Power Station






# PV Systems Configurations




## Central inverters

- 10 kW-250kW, three-phase, several strings in parallel
- High efficiency, low cost, low reliability, not optimal MPPT
- Used for power plants



## String (Multi)inverters

- 1.5-5 kW, typical residential application
- Each string has its own inverter enabling better MPPT
- The strings can have different orientations
- Three-phase inverters for power < 5kW



## Module inverters


- 50-180W, each panel has its own inverter enabling optimal MPPT
- Lower efficiency, difficult maintenance
- Higher cost/kWp

# Technical Description of a photovoltaic power plant

- PV modules
- supporting structure
- inverter(s)
  - central
  - decentral
- switchboards
- transformer for a conversion to a high voltage output



Tens of millions of PV modules installed



## 35 MW<sub>p</sub> power station in Veprek (20 km from Prague)



- 186 960 panels rated at 185W<sub>p</sub> and 190W<sub>p</sub> each (Phonosolar)
- 3300 SMA 10 kW and 11 kW inverters using a (multi)string configuration
- 26 transformers from 0.4kV to 22kV
- 1 transformer connects the total generated power to the 110 kV high voltage power line

# The procedure for detection and removal of operational failures

- fault in a PV module
- fault in interconnection (connectors / cables / switchboard)
- fault in inverter (monitoring system)

## A) Data collection system

- shows the performance of all inverters
- the problem is localized if a power loss appears on one inverter (relative to an average performance of all of the inverters)
- Comparison of normalized inverter yields for 23.11.2009 brings following detailed data:
  - Inverter '2000760653'  
SN: 2000760653  
Generator: 11,9 kWp  
Total yield: 20,97 kWh  
Specific yield: 1,76 kWh/kWp  
deviation >8% (8,7%)

# The exact localization of a problem could be found under „Plant Logbook“ on „Sunny Portal“ (www.sunnyportal.com)

The screenshot displays the 'Plant Logbook' interface for the plant 'FVE CZECH - Smirice I'. The left sidebar contains navigation options such as 'Plant selection', 'Plant Profile', 'Energy and Power', 'Yearly Comparison', 'Plant Monitoring', 'Plant Logbook: 152', 'Visualization', and 'User Information/Logout'. The main area shows a search filter for '30/05/2010' with a status of 'not confirmed' and 'all' devices. A table lists 15 log entries, all of which are 'Warning' type. A tooltip is visible over one of the entries, providing detailed information about a yield deviation.

	Plant/Devices	Time	Type	Description	Confirmed
<input type="checkbox"/>	2000760007	30/05/2010 11:30:42	Warning	Warten /Iso-resistance	✘
<input type="checkbox"/>	2000760007	30/05/2010 06:30:17	Warning	Warten /Iso-resistance	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:26	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:18	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:17	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:13	Warning	Yield de	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:11	Warning	Yield de "2000760566", total yield 45.9 kWh, specific yield 3.9 kWh/kWp, deviation 25.9% (>8%) compared to the average of monitored inverters (5.2 kWh/kWp on 28.5.2010).	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:02	Warning	Yield de	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:04:01	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:53	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:51	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:37	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:35	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:33	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:32	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	FVE CZECH - Smirice I	29/05/2010 15:03:31	Warning	Yield deviation from inverter comparison Inverter ...	✘
<input type="checkbox"/>	2000760082	29/05/2010 14:30:46	Warning	Netzueb. /Grid voltage L1	✘
<input type="checkbox"/>	2000760678	29/05/2010 14:30:35	Warning	MPP /Grid voltage L1	✘
<input type="checkbox"/>	2000760090	29/05/2010 14:30:26	Warning	Warten /Grid voltage L1	✘
<input type="checkbox"/>	2000759900	29/05/2010 14:30:10	Warning	Netzueb. /Grid voltage L1	✘

## B) visual checking the corresponding PV string

- disconnection of the module, missing or broken module, by obstruction that shades a module, melted or burned junction box, etc.

## C) checking the switchboard




- follows (broken fuses or disconnected breakers, destroyed over voltage protections)

## D) checking the faulty string



- should be done and voltage measurement conducted
- to localize a faulty connector, it is necessary to measure the modules as pairs

## E) check the temperature distribution

- under load over the modules can be evaluated using IR camera
- "Hot spot" appears together with the presence of local shading or when a single cell is cracked/damaged




Problematic parts of the PV system can be detected







# F) checking the I-V characteristic (in field)




## F) checking the I-V characteristic




A) Common I-V curve characteristics



B) Increased series resistance



C) Cracked or partially shaded cell




D) Interrupted chain of cells or completely shaded cell


## Changing defect parts

In the case of modules may be done more detail analyses

Precise I-V characteristic measurements



## Electroluminescence



# Conclusions

- During PV power plant operation, faults decreasing the total power output of the power plant may arise.
- It can either be a fault in a PV module, failure in a connection (connectors/cables/switchboard) or a failure in an inverter.
- The inverters are equipped with a monitoring system that observes the operating parameters, inputs and output and is able to identify most of the error states.
- The identification and removal of the fault should be carried out in a shortest possible time in order to minimize losses in energy production.